

Addendum of Tender Document

For

Procurement of 30-KVA Generators

IN RESPECT OF THE

IFB No. SEF/NP/15-16/51

With reference to the above Tender for Procurement of 30-kvA Generators, the point (3) of page no. 52 "specification of 30-KvA Generators may be read Engine: Cummins or Perkins or Equivalent " the correction page of 52 is enclosed for your perusal.

Issued By:



.....
Acting Deputy Director (Procurement),
Sindh Education Foundation,
Govt. of Sindh,
Karachi

DIESEL GENERATOR SET REQUIRED

CAPACITY: 30 KVA

Engine: Cummins or Perkins or Equivalent

INCLUDING FOLLOWING ACCESSORIES:

- ACOUSTIC CANOPY
- AMF / ATS PANEL
- Main Cable 40 meter (or as per need)
- WITH SUPPLY, INSTALLATION & COMMISSIONING & TESTING (With base cabling and etc), in following districts office in Sindh.

Larkana, Sukkur, Mirpukhas, Shaheed Banazirabad, Sehwan, Kharipur & Mithi.

ONE YEAR WARRANTY OF PARTS & SERVICES

